



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J1571

Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCES

Project Name: Annex Potsdam HS

Fred Hauck
20104 NYS Route 3
Watertown, NY 13601

Project / PO Number: N/A
Received: 10/25/2016 10:00
Reported: 11/30/2016 21:43

Analytical Testing Parameters

Client Sample ID: 1
Lab Sample ID: J6J1571-01
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/17/16
Collection Time: 07:26

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	<0.00100	0.015	0.00100	mg/L		11/23/16 1832	11/29/16 1632

Analytical Testing Parameters

Client Sample ID: 2
Lab Sample ID: J6J1571-02
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/17/16
Collection Time: 07:26

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	<0.00100	0.015	0.00100	mg/L		11/23/16 1832	11/29/16 1633

Analytical Testing Parameters

Client Sample ID: 3
Lab Sample ID: J6J1571-03
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/17/16
Collection Time: 07:27

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	<0.00100	0.015	0.00100	mg/L		11/23/16 1832	11/29/16 1634



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J1571

Analytical Testing Parameters

Client Sample ID: 5
Lab Sample ID: J6J1571-04
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/17/16
Collection Time: 07:28

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.015, 0.00100, mg/L, 11/23/16 1832, 11/29/16 1635

Analytical Testing Parameters

Client Sample ID: 6
Lab Sample ID: J6J1571-05
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/17/16
Collection Time: 07:28

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.015, 0.00100, mg/L, 11/23/16 1832, 11/29/16 1637

Analytical Testing Parameters

Client Sample ID: 7
Lab Sample ID: J6J1571-06
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/17/16
Collection Time: 07:29

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.015, 0.00100, mg/L, 11/23/16 1832, 11/29/16 1637

Laboratory

NY: Microbac Laboratories, Inc., New York Division

Definitions

- AL: Action Level
RL: Reporting Limit
G: Result fails applicable NYS drinking water standards

Cooler Receipt Log

Cooler ID: Default Cooler Temp: °C



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J1571

Cooler Inspection Checklist

Custody Seals Intact and/or No Evidence of Tampering	Yes	Containers Intact	Yes
COC/Labels Agree	Yes	Preservation Correct (or not required)	Yes
Received on Ice (or not required)	Yes		

Project Requested Certification(s)

Microbac Laboratories, Inc., New York Division	
NY Lab ID No.: 10795	New York State Department of Health
Microbac Laboratories, Inc. - Chicagoland	
NY Lab ID No: 12006	New York State Department of Health
PA DEP ID: 68-04863	Pennsylvania Department of Environmental Protection

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

Reviewed and Approved By:

Michael Fifield
Division Manager
11/30/2016 21:43

Go Green: Contact Michael Fifield to set up email reporting and invoicing options.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. For any feedback concerning our services, please contact Michael Fifield, Project Manager at michael.fifield@microbac.com. You may also contact Michael Fifield, Managing Director at michael.fifield@microbac.com or Robert Crookston, President at robert.crookston@microbac.com.

