



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6K0097

Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCES

Project Name: Potsdam HS

Fred Hauck
20104 NYS Route 3
Watertown, NY 13601

Project / PO Number: N/A
Received: 10/25/2016 10:00
Reported: 11/30/2016 18:17

Analytical Testing Parameters

Client Sample ID: Science - Ice
Lab Sample ID: J6K0097-01
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/17/16
Collection Time: 07:00

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	<0.00100	0.015	0.00100	mg/L		11/17/16 2036	11/22/16 0831

Analytical Testing Parameters

Client Sample ID: 57
Lab Sample ID: J6K0097-02
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/17/16
Collection Time: 07:02

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.00184	0.015	0.00100	mg/L		11/17/16 2036	11/22/16 0832

Analytical Testing Parameters

Client Sample ID: 59
Lab Sample ID: J6K0097-03
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/17/16
Collection Time: 07:04

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.0224	0.015	0.00100	mg/L		11/17/16 2036	11/22/16 0833



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6K0097

Analytical Testing Parameters

Client Sample ID: Gym - Ice
Lab Sample ID: J6K0097-04
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/17/16
Collection Time: 07:03

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.015, 0.00100, mg/L, 11/17/16 2036, 11/22/16 0835

Analytical Testing Parameters

Client Sample ID: 58
Lab Sample ID: J6K0097-05
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/17/16
Collection Time: 07:04

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0107, 0.015, 0.00100, mg/L, 11/17/16 2036, 11/22/16 0836

Analytical Testing Parameters

Client Sample ID: 56
Lab Sample ID: J6K0097-06
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/17/16
Collection Time: 06:58

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.015, 0.00100, mg/L, 11/17/16 2036, 11/22/16 0838



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6K0097

Analytical Testing Parameters

Client Sample ID: 36
Lab Sample ID: J6K0097-07
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/17/16
Collection Time: 06:36

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00547, 0.015, 0.00100, mg/L, 11/17/16 2036, 11/22/16 0839

Analytical Testing Parameters

Client Sample ID: 30
Lab Sample ID: J6K0097-08
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/17/16
Collection Time: 06:27

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.015, 0.00100, mg/L, 11/17/16 2036, 11/22/16 0839

Analytical Testing Parameters

Client Sample ID: 55
Lab Sample ID: J6K0097-09
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/17/16
Collection Time: 06:58

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00397, 0.015, 0.00100, mg/L, 11/17/16 2036, 11/22/16 0840



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6K0097

Analytical Testing Parameters

Client Sample ID: 53
Lab Sample ID: J6K0097-10
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/17/16
Collection Time: 06:56

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.015, 0.00100, mg/L, 11/17/16 2036, 11/22/16 0841

Analytical Testing Parameters

Client Sample ID: 54
Lab Sample ID: J6K0097-11
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/17/16
Collection Time: 06:56

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.015, 0.00100, mg/L, 11/17/16 2036, 11/22/16 0844

Analytical Testing Parameters

Client Sample ID: 72
Lab Sample ID: J6K0097-12
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/17/16
Collection Time: 07:13

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0473, 0.015, 0.00100, mg/L, 11/17/16 2036, 11/22/16 0845



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6K0097

Analytical Testing Parameters

Client Sample ID: 68
Lab Sample ID: J6K0097-13
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/17/16
Collection Time: 07:10

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.00235, 0.015, 0.00100, mg/L, 11/17/16 2036, 11/22/16 0846

Analytical Testing Parameters

Client Sample ID: 51
Lab Sample ID: J6K0097-14
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/17/16
Collection Time: 06:55

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.00100, 0.015, 0.00100, mg/L, 11/17/16 2036, 11/22/16 0846

Analytical Testing Parameters

Client Sample ID: 61
Lab Sample ID: J6K0097-15
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/17/16
Collection Time: 07:05

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.00483, 0.015, 0.00100, mg/L, 11/17/16 2036, 11/22/16 0847



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6K0097

Analytical Testing Parameters

Client Sample ID: 60
Lab Sample ID: J6K0097-16
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/17/16
Collection Time: 07:05

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0125, 0.015, 0.00100, mg/L, 11/17/16 2036, 11/22/16 0849

Analytical Testing Parameters

Client Sample ID: 66
Lab Sample ID: J6K0097-17
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/17/16
Collection Time: 07:10

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00711, 0.015, 0.00100, mg/L, 11/17/16 2036, 11/22/16 0850

Analytical Testing Parameters

Client Sample ID: 69
Lab Sample ID: J6K0097-18
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/17/16
Collection Time: 07:10

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0131, 0.015, 0.00100, mg/L, 11/17/16 2036, 11/22/16 0852



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6K0097

Analytical Testing Parameters

Client Sample ID: 71
Lab Sample ID: J6K0097-19
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/17/16
Collection Time: 07:13

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.015, 0.00100, mg/L, 11/17/16 2036, 11/22/16 0853

Analytical Testing Parameters

Client Sample ID: 65
Lab Sample ID: J6K0097-20
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/17/16
Collection Time: 07:09

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0191, 0.015, 0.00100, mg/L, 11/17/16 2036, 11/23/16 1858

Analytical Testing Parameters

Client Sample ID: 67
Lab Sample ID: J6K0097-21
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/17/16
Collection Time: 07:09

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0117, 0.015, 0.00100, mg/L, 11/17/16 2036, 11/22/16 0856



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6K0097

Analytical Testing Parameters

Client Sample ID: 64
Lab Sample ID: J6K0097-22
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/17/16
Collection Time: 07:07

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00895, 0.015, 0.00100, mg/L, 11/17/16 2036, 11/22/16 0856

Analytical Testing Parameters

Client Sample ID: 62
Lab Sample ID: J6K0097-23
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/17/16
Collection Time: 07:05

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.015, 0.00100, mg/L, 11/17/16 2036, 11/22/16 0857

Analytical Testing Parameters

Client Sample ID: 63
Lab Sample ID: J6K0097-24
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/17/16
Collection Time: 07:06

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.015, 0.00100, mg/L, 11/17/16 2036, 11/22/16 0858



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6K0097

Analytical Testing Parameters

Client Sample ID: 39
Lab Sample ID: J6K0097-25
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/17/16
Collection Time: 06:38

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.015, 0.00100, mg/L, 11/17/16 2036, 11/22/16 0859

Analytical Testing Parameters

Client Sample ID: 48
Lab Sample ID: J6K0097-26
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/17/16
Collection Time: 06:54

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0694, 0.015, 0.00100, mg/L, 11/17/16 2036, 11/22/16 0902

Analytical Testing Parameters

Client Sample ID: 37
Lab Sample ID: J6K0097-27
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/17/16
Collection Time: 06:36

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00351, 0.015, 0.00100, mg/L, 11/17/16 2036, 11/22/16 0903



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6K0097

Analytical Testing Parameters

Client Sample ID: 27
Lab Sample ID: J6K0097-28
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/17/16
Collection Time: 06:12

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.015, 0.00100, mg/L, 11/17/16 2036, 11/22/16 0904

Analytical Testing Parameters

Client Sample ID: 41
Lab Sample ID: J6K0097-29
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/17/16
Collection Time: 06:41

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00143, 0.015, 0.00100, mg/L, 11/17/16 2036, 11/22/16 0904

Analytical Testing Parameters

Client Sample ID: 47
Lab Sample ID: J6K0097-30
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/17/16
Collection Time: 06:50

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0172, 0.015, 0.00100, mg/L, 11/17/16 2036, 11/22/16 0905



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6K0097

Analytical Testing Parameters

Client Sample ID: 40
Lab Sample ID: J6K0097-31
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/17/16
Collection Time: 06:36

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.015, 0.00100, mg/L, 11/17/16 2036, 11/22/16 0907

Analytical Testing Parameters

Client Sample ID: 50
Lab Sample ID: J6K0097-32
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/17/16
Collection Time: 06:54

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0602, 0.015, 0.00100, mg/L, 11/17/16 2036, 11/22/16 0909

Analytical Testing Parameters

Client Sample ID: 46-1
Lab Sample ID: J6K0097-33
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/17/16
Collection Time: 06:50

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.015, 0.00100, mg/L, 11/17/16 2036, 11/22/16 0910



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6K0097

Analytical Testing Parameters

Client Sample ID: 46-2
Lab Sample ID: J6K0097-34
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/17/16
Collection Time: 06:51

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.015, 0.00100, mg/L, 11/17/16 2036, 11/22/16 0911

Analytical Testing Parameters

Client Sample ID: 38
Lab Sample ID: J6K0097-35
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/17/16
Collection Time: 06:37

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00506, 0.015, 0.00100, mg/L, 11/17/16 2036, 11/22/16 0911

Analytical Testing Parameters

Client Sample ID: 52
Lab Sample ID: J6K0097-36
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/17/16
Collection Time: 06:55

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.015, 0.00100, mg/L, 11/17/16 2036, 11/22/16 0914



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6K0097

Analytical Testing Parameters

Client Sample ID: 44-1
Lab Sample ID: J6K0097-37
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/17/16
Collection Time: 06:48

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.015, 0.00100, mg/L, 11/17/16 2036, 11/22/16 0914

Analytical Testing Parameters

Client Sample ID: 44-2
Lab Sample ID: J6K0097-38
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/17/16
Collection Time: 06:49

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.015, 0.00100, mg/L, 11/17/16 2036, 11/22/16 0915

Analytical Testing Parameters

Client Sample ID: 45-1
Lab Sample ID: J6K0097-39
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/17/16
Collection Time: 06:48

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.015, 0.00100, mg/L, 11/17/16 2036, 11/22/16 0916



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6K0097

Analytical Testing Parameters

Client Sample ID: 45-2
Lab Sample ID: J6K0097-40
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/17/16
Collection Time: 06:49

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.015, 0.00100, mg/L, 11/17/16 2036, 11/22/16 0918

Analytical Testing Parameters

Client Sample ID: 31
Lab Sample ID: J6K0097-41
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/17/16
Collection Time: 06:28

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0792, 0.015, 0.00100, mg/L, 11/17/16 2036, 11/22/16 0920

Analytical Testing Parameters

Client Sample ID: 8
Lab Sample ID: J6K0097-42
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/17/16
Collection Time: 05:55

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.015, 0.00100, mg/L, 11/17/16 2036, 11/22/16 0921



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6K0097

Analytical Testing Parameters

Client Sample ID: 9
Lab Sample ID: J6K0097-43
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/17/16
Collection Time: 05:55

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.015, 0.00100, mg/L, 11/17/16 2036, 11/22/16 0921

Analytical Testing Parameters

Client Sample ID: 13
Lab Sample ID: J6K0097-44
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/17/16
Collection Time: 05:56

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.015, 0.00100, mg/L, 11/17/16 2036, 11/22/16 0922

Analytical Testing Parameters

Client Sample ID: 17
Lab Sample ID: J6K0097-45
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/17/16
Collection Time: 06:01

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.015, 0.00100, mg/L, 11/17/16 2036, 11/22/16 0923



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6K0097

Analytical Testing Parameters

Client Sample ID: 16
Lab Sample ID: J6K0097-46
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/17/16
Collection Time: 06:01

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.015, 0.00100, mg/L, 11/17/16 2036, 11/22/16 0926

Analytical Testing Parameters

Client Sample ID: 2
Lab Sample ID: J6K0097-47
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/17/16
Collection Time: 05:39

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00944, 0.015, 0.00100, mg/L, 11/17/16 2036, 11/22/16 0927

Analytical Testing Parameters

Client Sample ID: 30
Lab Sample ID: J6K0097-48
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/17/16
Collection Time: 06:16

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.015, 0.00100, mg/L, 11/17/16 2036, 11/22/16 0928



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6K0097

Analytical Testing Parameters

Client Sample ID: 15
Lab Sample ID: J6K0097-49
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/17/16
Collection Time: 06:00

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.00100, 0.015, 0.00100, mg/L, 11/17/16 2036, 11/22/16 0929

Analytical Testing Parameters

Client Sample ID: 29
Lab Sample ID: J6K0097-50
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/17/16
Collection Time: 06:16

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.00100, 0.015, 0.00100, mg/L, 11/17/16 2036, 11/22/16 0929

Analytical Testing Parameters

Client Sample ID: 19
Lab Sample ID: J6K0097-51
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/17/16
Collection Time: 06:02

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.00100, 0.015, 0.00100, mg/L, 11/17/16 2036, 11/22/16 0930



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6K0097

Analytical Testing Parameters

Client Sample ID: 7
Lab Sample ID: J6K0097-52
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/17/16
Collection Time: 05:43

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00662, 0.015, 0.00100, mg/L, 11/17/16 2036, 11/22/16 0931

Analytical Testing Parameters

Client Sample ID: 4
Lab Sample ID: J6K0097-53
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/17/16
Collection Time: 05:42

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.015, 0.00100, mg/L, 11/17/16 2036, 11/22/16 0931

Analytical Testing Parameters

Client Sample ID: 6
Lab Sample ID: J6K0097-54
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/17/16
Collection Time: 05:43

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00314, 0.015, 0.00100, mg/L, 11/17/16 2036, 11/22/16 0932



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6K0097

Analytical Testing Parameters

Client Sample ID: 32
Lab Sample ID: J6K0097-55
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/17/16
Collection Time: 06:28

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0342, 0.015, 0.00100, mg/L, 11/17/16 2036, 11/22/16 0933

Analytical Testing Parameters

Client Sample ID: 28
Lab Sample ID: J6K0097-56
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/17/16
Collection Time: 06:12

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.015, 0.00100, mg/L, 11/17/16 2036, 11/22/16 0935

Analytical Testing Parameters

Client Sample ID: 25
Lab Sample ID: J6K0097-57
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/17/16
Collection Time: 06:11

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00771, 0.015, 0.00100, mg/L, 11/17/16 2036, 11/22/16 0936



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6K0097

Analytical Testing Parameters

Client Sample ID: 33
Lab Sample ID: J6K0097-58
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/17/16
Collection Time: 06:33

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.015, 0.00100, mg/L, 11/17/16 2036, 11/22/16 0936

Analytical Testing Parameters

Client Sample ID: 42
Lab Sample ID: J6K0097-59
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/17/16
Collection Time: 06:42

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.015, 0.00100, mg/L, 11/17/16 2036, 11/22/16 0937

Analytical Testing Parameters

Client Sample ID: 35
Lab Sample ID: J6K0097-60
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/17/16
Collection Time: 06:35

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0756, 0.015, 0.00100, mg/L, 11/17/16 2036, 11/22/16 0938



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6K0097

Analytical Testing Parameters

Client Sample ID: 3
Lab Sample ID: J6K0097-61
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/17/16
Collection Time: 05:39

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00589, 0.015, 0.00100, mg/L, 11/17/16 2036, 11/22/16 0940

Analytical Testing Parameters

Client Sample ID: 1
Lab Sample ID: J6K0097-62
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/17/16
Collection Time: 05:39

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00438, 0.015, 0.00100, mg/L, 11/17/16 2036, 11/22/16 0941

Analytical Testing Parameters

Client Sample ID: 70
Lab Sample ID: J6K0097-63
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/17/16
Collection Time: 07:12

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0558, 0.015, 0.00100, mg/L, 11/17/16 2036, 11/22/16 0941



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6K0097

Analytical Testing Parameters

Client Sample ID: 14
Lab Sample ID: J6K0097-64
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/17/16
Collection Time: 06:51

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00265, 0.015, 0.00100, mg/L, 11/17/16 2036, 11/22/16 0944

Analytical Testing Parameters

Client Sample ID: 34
Lab Sample ID: J6K0097-65
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/17/16
Collection Time: 06:35

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0661, 0.015, 0.00100, mg/L, 11/17/16 2036, 11/22/16 0944

Analytical Testing Parameters

Client Sample ID: 49
Lab Sample ID: J6K0097-66
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/17/16
Collection Time: 06:54

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0969, 0.015, 0.00100, mg/L, 11/17/16 2036, 11/22/16 0945



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6K0097

Analytical Testing Parameters

Client Sample ID: 29
Lab Sample ID: J6K0097-67
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/17/16
Collection Time: 06:26

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.015, 0.00100, mg/L, 11/17/16 2036, 11/22/16 0946

Analytical Testing Parameters

Client Sample ID: 26
Lab Sample ID: J6K0097-68
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/17/16
Collection Time: 06:11

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00648, 0.015, 0.00100, mg/L, 11/17/16 2036, 11/22/16 0946

Analytical Testing Parameters

Client Sample ID: 12
Lab Sample ID: J6K0097-69
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/17/16
Collection Time: 05:57

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.015, 0.00100, mg/L, 11/17/16 2036, 11/22/16 0947



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6K0097

Analytical Testing Parameters

Client Sample ID: 18
Lab Sample ID: J6K0097-70
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/17/16
Collection Time: 06:02

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.015, 0.00100, mg/L, 11/17/16 2036, 11/22/16 0948

Analytical Testing Parameters

Client Sample ID: 11
Lab Sample ID: J6K0097-71
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/17/16
Collection Time: 05:57

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00154, 0.015, 0.00100, mg/L, 11/17/16 2036, 11/22/16 0949

Analytical Testing Parameters

Client Sample ID: 10
Lab Sample ID: J6K0097-72
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/17/16
Collection Time: 05:56

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.015, 0.00100, mg/L, 11/17/16 2036, 11/22/16 0949



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6K0097

Analytical Testing Parameters

Client Sample ID: 24
Lab Sample ID: J6K0097-73
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/17/16
Collection Time: 06:10

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00121, 0.015, 0.00100, mg/L, 11/17/16 2036, 11/22/16 0950

Analytical Testing Parameters

Client Sample ID: 21
Lab Sample ID: J6K0097-74
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/17/16
Collection Time: 06:09

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00384, 0.015, 0.00100, mg/L, 11/17/16 2036, 11/22/16 0952

Analytical Testing Parameters

Client Sample ID: 20
Lab Sample ID: J6K0097-75
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/17/16
Collection Time: 06:09

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00386, 0.015, 0.00100, mg/L, 11/17/16 2036, 11/22/16 0953



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6K0097

Analytical Testing Parameters

Client Sample ID: 23
Lab Sample ID: J6K0097-76
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/17/16
Collection Time: 06:10

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.015, 0.00100, mg/L, 11/17/16 2036, 11/22/16 0954

Analytical Testing Parameters

Client Sample ID: 43
Lab Sample ID: J6K0097-77
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/17/16
Collection Time: 06:42

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.015, 0.00100, mg/L, 11/17/16 2036, 11/22/16 0954

Laboratory

NY: Microbac Laboratories, Inc., New York Division

Definitions

AL: Action Level
RL: Reporting Limit
G: Result fails applicable NYS drinking water standards

Cooler Receipt Log

Cooler ID: Default Cooler Temp: °C

Cooler Inspection Checklist

Table with 4 columns: Item, Yes, No, Yes. Rows: Custody Seals Intact and/or No Evidence of Tampering, COC/Labels Agree, Received on Ice (or not required)

Project Requested Certification(s)

Microbac Laboratories, Inc., New York Division NY Lab ID No.: 10795 New York State Department of Health
Microbac Laboratories, Inc. - Chicagoland NY Lab ID No: 12006 Pennsylvania Department of Environmental Protection
PA DEP ID: 68-04863



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6K0097

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

Reviewed and Approved By:

A handwritten signature in blue ink that reads "Michael Fifield".

Michael Fifield
Division Manager
11/30/2016 18:17

Go Green: Contact Michael Fifield to set up email reporting and invoicing options.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. For any feedback concerning our services, please contact Michael Fifield, Project Manager at michael.fifield@microbac.com. You may also contact Michael Fifield, Managing Director at michael.fifield@microbac.com or Robert Crookston, President at robert.crookston@microbac.com.

3821 Buck Drive
 Corland NY 13045
 Phone: (607) 753-3403 Fax: (607) 753-3415
 NY #10795, EPA #NY000935

Potsdam
 MS

Microbac Laboratories, Inc.
CHAIN OF CUSTODY
 Samples must be returned on ice
 MNY Workorder # 577



J6K0097

Client Information		Billing/Invoice:		Analysis Requested		Recalling Info. (Lab Use Only)	
Name:	Jefferson-Lewis-Hamilton-Herkimer-Onesida ROCES			Ice:	YES NO	Container Material	YES NO
Address:	20104 NYS Route 3			Cooler:	YES NO	Container Size (in MI)	YES NO
Contact:	Watertown, NY 13601			Sample Temp:		Preservative	
Phone:	Ray Filley			Cooler Seel:	YES NO	Accepted?	YES NO
Project:	Lead Testing			Pickup:	YES NO		
Quote ID:				Dropoff:	C W		
Rush TAT Bur. Days:	2-5 5-7 7-10						
Release to DOH: Yes							
Email Results: Yes	rfilley@boces.com						
Fax Results: Yes	rfilley@boces.com / ffilley@boces.com						

Sample Information			Number of Containers for Analysis Requested		Comments/Field Data
Description/Location	Date	Time	Initial	Matrix Type	
1 Science - ILE	10/17/16	7:00	YD		
2 57		7:02			
3 59		7:04			
4 Gym - Ice		7:02			
5 57		7:04			
6 56		6:58			
7 30		6:30			
8 30		6:27			

Print Name and Company	Signature	Date/Time	Comments
Sampled: Linda Shaw	<i>Linda Shaw</i>	10/24 1pm	
Received: Alayna Dawson	<i>Alayna Dawson</i>	10/25/16 1000	
Received:			
Received:			
Received:			
Received:			

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory.
 By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with the terms and conditions of the subcontract.

3821 Buck Drive
 Cortland NY 13045
 Phone:(607)753-3403 Fax:(607)753-3415
 NY #10795, EPA #NY00936

Potsdam
 MS

Microbac Laboratories, Inc.
CHAIN OF CUSTODY

Samples must be returned on ice
 MNY Workorder #

Client Information			Billing/Invoice:		
Name:	Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCES				
Address:	20104 NYS Route 3 Watertown, NY 13601				
Contact:	Ray Filley				
Phone:	315-779-7054				
Project:	Lead Testing				
Quote ID:		PO#:			
Rush TAT Bus. Days:	2-5	5-7	7-10	Date Req.:	
Release to DOH:	Yes				
Email Results:	Yes	rfilev@boces.com / fhack@boes.com			
Fax Results:	Yes				

Sample Information			Analysis Requested			Receiving Info (Lab Use Only)		
Description/Location	Date	Time	Initial	Matrix Type	Number of Containers for Analysis Requested	Container Material	Container Size (in MI)	Prefeructive
55	10/17/16	6:55	YB					
53		6:50						
54		6:50						
72		7:10						
39		7:10						
51		6:50						
61		7:10						
60		7:15						

Print Name and Company	Signature	Date/Time	Comment:
Sampled: Linda Shaw	Linda Shaw	10/24 1pm	
Received:			
Received:			
Received:			
Received:			
Received:			

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory.
 By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with the terms and conditions of the subcontract.

3621 Buck Drive
 Cortland NY 13045
 Phone:(607)753-3403 Fax:(607)753-3415
 NY #10795, EPA #NY00935

Potsdam
 MS

Microbac Laboratories, Inc. CHAIN OF CUSTODY

3000
 Samples must be returned on ice

MNY Workorder #

Client Information			Billing/Invoice:			Analysis Requested			Receiving Info (Lab Use Only)			
Name:	Jefferson-Lewis-Hamilton-Herkimer-Oneida POCES								Ice:	YES	NO	
Address:	20104 NYS Route 3 Watertown, NY 13601								Cooler:	YES	NO	
Contact:	Ray Filley								Sample Temp:			
Phone:	315-779-7054								Cooler Seal:	YES	NO	
Project:	Lead Testing								Pickup:	YES	NO	
Quote ID:		PO#:							Dropoff:	C	W	
Rush TAT Bus. Days:	<2	2-5	5-7	7-10	Date Req.:				Accepted?:	YES	NO	
Release to DOH: Yes									Container Material:			
Email Results: Yes		rfilley@poces.com							Container Size (in Mil):			
Fax Results: Yes		rfilley@poces.com / ffilley@poces.com							Preservative:			
Sample Information			Matrix			Number of Containers for Analysis Requested			Comments/Field Data			
Description/Location	Date	Time	Initial	Matrix	Type							
666	10/17/16	7:10	YB									
669		7:10										
671		7:13										
655		7:09										
667		7:09										
664		7:07										
662		7:05										
663		7:06										
Print Name and Company						Signature			Date/Time			
Sampled: Linda Shaw						Linda Shaw			10/24 1pm			
Received:												
Received:												
Received:												
Received:												
Received:												

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory.
 By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this.

3821 Buck Drive
 Cortland NY 13045
 Phone:(607)753-3403 Fax:(607)753-3415
 NY #10795, EPA #NY009935

Potsdam
 MS

Microbac Laboratories, Inc.
CHAIN OF CUSTODY

② ⑥ ⑩

MNY Workorder #

Client Information		Billing/Invoice:		Analysis Requested		Receiving Info (Lab Use Only)	
Name:	Jefferson-Lewis-Hamilton-Herkimer-Onida BOCES					Ice:	YES NO
Address:	20104 NYS Route 3					Cooler:	YES NO
Contact:	Watertown, NY 13601					Sample Temp:	
Phone:	Ray Filley					Cooler Seal:	YES NO
Project:	Lead Testing					Pickup:	YES NO
Quote ID:		PO#:				Dropoff:	C W
Rush TAT Bus. Days:	<3 2-5 5-7 7-10	Date Req.:				Accepted?	YES NO
Release to DOH: Yes						Container Material:	
Email Results: Yes	rfilley@boces.com / ffilley@boes.com					Container Size (in ML)	
Fax Results: Yes						Preservative	
Sample Information		Matrix Type		Number of Containers for Analysis Requested		Comments/Field Data	
Description/Location	Date	Time	Initial				
1 39	10/17/16	6:32	YR				
2 42		6:54					
3 37		6:36					
4 27		6:12					
5 41		6:41					
6 47		6:50					
7 40		6:36					
8 50		6:54					
Print Name and Company		Signature		Date/Time		Comments	
Sampled: Linda Shaw		Linda Shaw		10/24 1pm			
Received:							
Received:							
Received:							
Received:							
Received:							

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory.
 By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this.

3621 Buck Drive
 Cortland NY 13045
 Phone:(607)753-3403 Fax:(607)753-3415
 NY #10795, EPA #NY00935

Potsdam
 MS

Microbac Laboratories, Inc. CHAIN OF CUSTODY

50010
 Samples must be returned on ice

MNY Workorder #

Client Information		Billing/Invoicing		Analysis Requested		Receiving Info (Lab Use Only)	
Name:	Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCES					Ice:	YES NO
Address:	20104 NYS Route 3 Watertown, NY 13601					Cooler:	YES NO
Contact:	Ray Filley					Sample Temp:	YES NO
Phone:	315-779-7054					Cooler Seal:	YES NO
Project:	Lead Testing					Pickup:	YES NO
Quote ID:		PO#:				Dropoff:	C W
Rush TAT Bus. Days:	<2 2-5 5-7 7-10	Date Req.:				Accepted?	YES NO
Release to DOH: Yes						Container Material	
Email Results: Yes	filley@boces.com					Container Size (in Mil)	
Fax Results: Yes	ffhack@boces.com					Preservative	
Sample Information		Matrix		Number of Containers for Analysis Requested		Comments/Field Data	
Description/Location	Date	Time	Initial	Type			
1 46-1	10/17/16	6:50	YB				
2 46-2		6:51					
3 37		6:51					
4 52		6:55					
5 44-1		6:47					
6 44-2		6:49					
7 45-1		6:47					
8 45-2		6:49					
Print Name and Company		Signature		Date/Time		Comments	
Sampled: Linda Shaw		Linda Shaw		10/24 1pm			
Received:							
Received:							
Received:							
Received:							
Received:							

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory.
 By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with that.

3821 Buck Drive
 Corland NY 13045
 Phone: (607) 753-3403 Fax: (607) 753-3415
 NY #10795, EPA #NY00935

Potsdam
 HS

Microbac Laboratories, Inc. CHAIN OF CUSTODY

6 of 10
 Samples must be returned on ice

MNY Workorder #

Client Information		Billing/Invoice:		Analysis Requested		Receiving Info (Lab Use Only)	
Name:	Jefferson-Lewis-Hamilton-Heckimer, Oncaida, BOCES					Ice:	YES NO
Address:	20104 NYS Route 3 Watertown, NY 13601					Cooler:	YES NO
Contact:	Ray Filley					Sample Temp:	
Phone:	315-779-7054					Cooler seal:	YES NO
Project:	Lead Testing					Pickup:	YES NO
Quote ID:		PO#:				Dropoff:	C W
Rush TAT Bus. Days:	42 2-5 5-7 7-10	Date Req.:				Accepted?	YES NO
Relate to DOH:	Yes					Container Material	
Email Results:	Yes	rfilley@boces.com / rfilley@poc5.com				Container size (in MI)	
Fax Results:	Yes					Preservative	
Sample Information		Number of Containers for Analysis Requested		Comments/Field Data			
Description/Location	Date	Time	Initial	Matrix Type			
1 31	10/17/16	6:22	YSA				
2 2		5:55					
3 9		5:55					
4 13		5:56					
5 17		6:01					
6 16		6:01					
7 8		5:59					
8 30		6:16					
Sampled: Linda Shaw		Signature: Linda Shaw		Date/Time: 10/24 1pm			
Received:							
Received:							
Received:							
Received:							
Received:							

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory.
 By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with it.

70010

Microbac Laboratories, Inc.
CHAIN OF CUSTODY

Potsdam
 MS

200.8 Lead

MNY Workorder #

Client Information		Billing/Invoice:		Analysis Requested		Receiving Info (Lab Use Only)	
Name:	Jefferson-Lewis-Hamilton-Herkimer-Oswego BOCES			Ice:	YES NO	Ice:	YES NO
Address:	20104 NYS Route 3 Watertown, NY 13601			Cooler:	YES NO	Cooler:	YES NO
Contact:	Ray Filley			Sample Temp:		Sample Temp:	
Phone:	315-779-7054			Cooler Seal:	YES NO	Cooler Seal:	YES NO
Project:	Lead Testing			Pickup:	YES NO	Pickup:	YES NO
Quote ID:				Dropoff:	C W	Dropoff:	C W
Ruth TAT Bur. Days:	< 2-5 5-7 7-10			Accepted?	YES NO	Accepted?	YES NO
Release to DOH:	Yes			Container Material:		Container Material:	
Email Results:	Yes			Container Size (in ml):		Container Size (in ml):	
Fax Results:	Yes			Preservative:		Preservative:	
				Comment/Field Data:		Comment/Field Data:	
Sample Information		Matrix Type		Number of Containers for Analysis Requested			
Description/Location	Date	Time	Initial				
1 15	10/17/16	6:00	YJS				
2 29		6:16					
3 19		6:22					
4 7		5:43					
5 4		2:42					
6 6		5:48					
7 32		6:27					
8 28		6:0					
Print Name and Company			Signature		Date/Time		Comments
Sampled: Linda Shaw			Linda Shaw		10/24 Apr		
Received:							
Received:							
Received:							
Received:							
Received:							

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory.
 By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement to do so.

3821 Buck Drive
 Corland NY 13045
 Phone:(607)753-3403 Fax:(607)753-3416
 NY #10795, EPA #NY00935

POTSdam
 WAS

Microbac Laboratories, Inc. Samples must be returned on ice

CHAIN OF CUSTODY

MNY Workorder #

Client Information			Billing/Invoice:		
Name: Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCES			Analytix Requested		
Address: 20104 NYS Route 3			Ice: YES NO		
Contact: Ray Filley			Cooler: YES NO		
Phone: 315-779-7054			Sample Temp: YES NO		
Project: Lead Testing			Cooler Seal: YES NO		
Quote ID:			Pickup: YES NO		
Rush TAT Bus. Days: 2-5 5-7 7-10			Dropoff: C W		
Release to DOH: Yes			Accepted? YES NO		
Email Results: Yes			Container Material		
Fax Results: Yes			Container size(In MI)		
Email Results: rfilley@boces.com			Preservative		
Fax Results: fhuck@boces.com			Comments/Field Data		
Sample Information			Number of Containers for Analysis Requested		
Description/Location	Date	Time	Initial	Matrix Type	
1 85	10/17/16	6:11	UJA		
2 33		6:38			
3 42		6:40			
4 35		6:35			
5 3		6:59			
6 1		8:39			
7 70		7:12			
8 14		6:50			
Print Name and Company			Signature		
Sampled: Linda Shaw			Linda Shaw		
Received:			Date/Time		
Received:			10/24 2pm		
Received:			Comments		
Received:					
Received:					

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this condition.

3821 Buck Drive
 Cortland NY 13046
 Phone:(607)753-3403 Fax:(607)753-3415
 NY #10795, EPA #NY000935

Putnam HS

Microbac Laboratories, Inc. CHAIN OF CUSTODY

Samples must be returned on ice
 MNY Workorder #

90610

Client Information		Billing/Invoice:		Analysis Requested	
Name:	Jelerson-Lewis-Hamilton-Herkimer-Otsego BOCES				
Address:	20104 NYS Route 3 Watertown, NY 13601				
Contact:	Ray Filley				
Phone:	315-779-7054				
Project:	Lead Testing				
Quote ID:					
Rush TAT Bur. Days:	2-5 5-7 7-10	PO#:			
Relays to DOH:	Yes	Date Req.:			
Email Results:	Yes				
Fax Results:	Yes				
	filley@boces.com / fhack@boces.com				
Sample Information					
Description/Location	Date	Time	Initial	Matrix Type	
1 34	10/17/10	6:35	VF		
2 49		6:51			
3 29		6:56			
4 26		5:57			
5 12		6:09			
6 13		5:57			
7 11		5:56			
8 10					
Print Name and Company		Signature		Date/Time	
Sampled: Linda Snow		Linda Snow		10/18/10	
Received:					
Received:					
Received:					
Received:					
Received:					
Comments					
Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this.					

3821 Buck Drive
 Corland NY 13046
 Phone:(607)753-3403 Fax:(607)753-3415
 NY #10795, EPA #NY000935

10 9610

Microbac Laboratories, Inc.
CHAIN OF CUSTODY

Samples must be returned on ice
 MNY Workorder #

Client Information		Billing/Invoicing:		Analysts Requested		Receiving Info (Lab Use Only)	
Name: Jefferson-Lewis-Hardin-Herkimer, Onelda BOCES		Address: 20104 NYS Route 3		Water town, NY 13601		Ice: YES NO	
Contact: Ray Filley		Phone: 315-779-7054		Project: Lead Testing		Cooler: YES NO	
Quote ID:		Rush TAT Bus. Days: 2-5 5-7 7-10		Date Rec.:		Sample Temp: YES NO	
Release to DOM: Yes		Email Results: Yes		Fax Results: Yes		Pickup: YES NO	
PO#:		200.8 Lead		P		Dropoff: C W	
Sample Information		Matrix Type		Number of Containers for Analysis Requested		Accepted? YES NO	
Description/Location		Date		Time		Initial	
1 84		10/14/10		6:10		JD	
2 81		10/14/10		6:02			
3 80		10/14/10		6:09			
4 83		10/14/10		6:10			
5 43		10/14/10		6:12			
6							
7							
8							
Print Name and Company		Signature		Date/Time		Comment:	
Sampled: Link Snow		Dinda Snow		10/24 1pm			
Received:							
Received:							
Received:							
Received:							
Received:							
Comments/Field Data							

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory.
 By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this.